

LTB

Laboratorium Techniki Budowlanej s.c.
 B. Wojtowicz, A. Żyła, M. Żyła
 41-306 Dąbrowa Górnicza, ul. Laski 83
 NIP 625-21-29-966
 Numer notyfikacji/Notified body/ 1827



tel/ fax (0-...)(32) 26 44 079; tel. (0-608) 50 66 32, (0-608) 50 66 35
 Bank Śląski o/Dąbrowa Górnicza nr 57 1050 1272 1000 0022 3368 1416

AB 661


Appendix No 2 to test report 722/B-2012

**Initial Type Testing Certificate
 pertinent to Standard EN 14351-1+A1
 No 722/B – 2012**

Laboratorium Techniki Budowlanej used the calculation method, in accordance with Standard EN ISO 10077-1:2006 and EN ISO 10077-2:2003, to define the thermal insulation of the windows of *NORD LINE* system, described in test report 722/B-2012, manufactured by:

aluplast® sp. z o.o.
 ul. Gołężycka 25A
 61-357 Poznań

Test's results	
Cross section	Frame / sash
U_f [W/m ² K]	1,3
Ψ [W/mK]	0,063
U_g [W/m ² K]	1,0
U_w [W/m ² K] for window 1,23x1,48 m	1,2
The results of the examination refer only to the tested sample and the test conditions. The parameters for other objects should be declared in compliance with the provisions specified in standard EN 14351-1+A1	



Quality Manager

uz. Maciej Żyła

mgr inż. Andrzej Żyła



Engineering Manager

Bogdan Wojtowicz
 mgr inż. Bogdan Wójtowicz

Dąbrowa Górnicza, dated 14th March, 2012